



TAMILNADU FIRE AND RESCUE SERVICE

SCHOOL NO OBJECTION CERTIFICATE

R.C.NO: 546 /V/SPR/2023

DATED:06.07.2023


Certificated that the M/S.MONTFORT SCHOOL, at Survey No. 259/1, 259/2, 260/7, Therasapuram, Vadagal 'B' Village, Pondur Post, Sriperumbudur Taluk, Kancheepuram District comprised of Ground Floor and 2 upper floors occupied by M/s.MONTFORT SCHOOL have Fire Service Rules, and verified by the officers concerned of Fire Service on 06.07.2023 in the presence of PRINCIPAL, M/s.MONTFORT SCHOOL, Survey No. 259/1, 259/2, 260/7, Therasapuram, Vadagal 'B' Village, Pondur Post and that the building/premises is for occupancy class School Premises With effect from 06/07/2023 for a period of 05/07/2024 Years in accordance with rule and subject to compliance of the conditions.

CONDITIONS

1. This License is valid for One year from the date of issue.
2. Fire Safety Systems should be maintained in good working condition.
3. Mock drill to be conducted periodically with the help of local fire brigade.
4. Any erection of permanent or temporary structure should be intimated to this department.
5. Further to limit the occupant load and to ensure better fire and life safety measures the following additional measures are insisted.
6. a) Building occupancy capacity should not be more than 4 people per Sq. meter as per The National Building Code-2016.
b) The staircase treads and flooring shall be treated with rough finish (Grooving) to Avoid falling of children.
c) As per Para 6.3 of the BIS Standards IS 14435:1997 as the classrooms have only One entrance, the capacity of the class room shall have to be limited to 45 students.

TO:

M/s. Montfort School,
S.No. 259/1, 259/2, 260/7, Therasapuram,
Vadagal 'B' Village, Pondur Post,
Sriperumbudur Taluk,
Kancheepuram District.


Station Officer,
Fire and Rescue Service,
Sriperumbudur.

Copy to : District officer, Kanchipuram.