

BUILDING SAFETY CERTIFICATE

No. 05/PE-KANCHEEPURAM

Dated : 05.04.2025

Certified that the **MONFORT SCHOOL**, Vadakal 'B' Village, Theresapuram, Pondur Post, Sriperumbudur Taluk, Kancheepuram District – 602 105, comprised of **Ground, First & Second Floors** owned / occupied by **MONFORT SCHOOL** have complied with the Building Bye Laws in accordance with rule of State / UT, and incorporate the provisions of building safety as specified in National Building Code 2005, 2016 and as amended thereafter and has been verified by the concerned officer on **31.03.2025** in the presence of **Bro.Antony Samy.A**, Correspondent & Principal, **MONFORT SCHOOL**, and that the said above building / premises is safe and fit for running School with effect from **01.04.2025** for a period of Three years only in accordance with rules.

Issued on 05.04.2025 at Kancheepuram by

Signature with Seal :

E. D. NATARAJAN, B.E., (CIVIL) ME
Chartered Engineer
Panel Engineer Class 1A
Kancheepuram District
4, Vanthavasi Road,
Gandhi Nagar,
Kancheepuram - 631 501.
Cell: 94431 06470, 8056831312

Er. D.NATARAJAN, B.E.(CIVIL),M.I.E.,
STRUCTURAL ENGINEER, CHARTERED ENGINEER
REGISTERED&APPROVED ENGINEER
BY THE BOARD OF ENGINEERS, TAMIL NADU.
PANEL ENGINEER CLASS IA, KANCHEEPURAM DISTRICT

Ref: Collector, Kpm, Lr. No: RC 23640/2011/M1 Dated 19.05.2012

Res: 50-A,3rd Street, S.S.Nagar.
Palanipet, Arakkonam – 631002
Off: #4, Vanthavasi Road,
Gandhi nagar,
Kanchipuram - 631501
Cell: 9443106470, 8056631312
Email : dnatarajan8@gmail.com

STRUCTURAL SOUNDNESS CERTIFICATE RELATING TO SCHOOL
STATEMENT ACCOMPANYING FORM - A

1. Name of the School and Door no of the Building : **MONFORT SCHOOL**
Vadakal "B" Village, Theresapuram, Pondur Post,
Sriperumbudur Taluk, Kancheepuram District – 602 105
2. Location (street No. Ward No. Name of place, ie., Corporation, Municipality/ Panchayat Union/ Panchayat/Township/Cantonment) : S.F.Nos. 259/1, 2 & 260/7
Vadakal "B" Village, Theresapuram, Pondur Post,
Sriperumbudur Taluk,
Kancheepuram District – 602 105
3. Year of construction : **BLOCK I**: Ground Floor : RCC Roof : 2015 & 2021
First Floor :RCC Roof : 2016; Second Floor : RCC Roof : 2017
BLOCK II: Ground & First Floor : RCC Roof : 2024
4. Approximates cost of construction as per current rate : Rs. 1100.00 Lakhs
5. Purpose for which the building is being used or proposed to be used : Educational
6. Purpose for which the building has hitherto been used : Educational
7. Details of construction of the building (particulars of the foundation, soil, Specification of various parts under
(i) Foundation : RCC Column & Footing
(ii) Basement : RCC Column, Plinth Beam & Brick in CM
(iii) Superstructure : RCC Column & Brick in CM
(iv) Floor & Roof are to be given) : Flooring: Cuddapah Stone & Tiles
Roof: RCC Slab
8. Period for which the license is require : May be issued FROM **01.04.2025 to 31.03.2028**
(For Three years only)
9. Number of persons to be accommodated Refer ANNEXURE to this : **One Thousand Seven Hundred Sixty (1760) Pupils only**

Place : Kancheepuram

Date : 05.04.2025

Signature of the Principal


Signature of the Engineer
Er. D. NATARAJAN, B.E.(CIVIL),M.I.E.
Chartered Engineer
Panel Engineer Class 1A
Kanchipuram District
4, Vanthavasi Road,
Gandhi Nagar,
Kanchipuram - 631 501.
Cell: 94431 06470, 8056631312

மரம் வளர்ப்போம்.



மழை பெறுவோம்

Er. D.NATARAJAN, B.E.(CIVIL),M.I.E.,
STRUCTURAL ENGINEER, CHARTERED ENGINEER
REGISTERED&APPROVED ENGINEER
BY THE BOARD OF ENGINEERS, TAMIL NADU.
PANEL ENGINEER CLASS IA, KANCHEEPURAM DISTRICT

Res: 50-A,3rd Street, S.S.Nagar.
Palanipet, Arakkonam - 631002
Off: #4, Vanthavasi Road,
Gandhi nagar,
Kanchipuram - 631501
Cell: 9443106470, 8056631312
Email : dnatarajan8@gmail.com

FORM - B

STATEMENT ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

MONFORT SCHOOL, VADAKAL 'B' VILLAGE, THERESAPURAM

FORM OF CERTIFICATE OF STRUCTURAL SOUNDNESS UNDER TAMILNADU COMBINED DEVELOPMENT AND BUILDING RULES 2019.

I Certify, that I have inspected the building mentioned in the statement and furnished below its salient technical features.

1. **Foundation:**


- i. **Depth below ground level** : 06 ft below G.L
ii. **Nature of soil met out in the foundation** : Hard Soil
iii. **Pressure at foundation** : Within the permissible limit
iv. **Probable safe bearing capacity of the foundation** : 20 tones / Sq.m

2. **Superstructure:**

- i. **Maximum stress in most critical** a) R.C.C Concrete : Within the permissible limit
Sections of masonry and concrete b) Masonry : Within the permissible limit
ii. **Nature of masonry and concrete** : Brick masonry in cm: 30 tones / Sq.m.
And its safe permissible stress R.C.C : 40 Kg / Sq.cm.

The Structural of the building has been verified by me with reference to ISIS loading standards 875 (Latest version) and other relevant Indian Standard code of practices I declare that the building is structurally sound to bCEe used as a public building for the purpose noted in the statement. This Certificate does not include any Thatched sheds and also any flammable building material utility. Proper toilet facilities to be provided as per norms. If any thatched sheds are found at a later period after issue of this certificate / License this certificate gets invalid. A license may be granted for the period from 01.04.2025 to 31.03.2028.

Signature of the Principal


Signature of the Engineer
D.NATARAJAN, B.E.(CIVIL),M.I.E.
Chartered Engineer
Panel Engineer Class 1A
Kanchipuram District
4, Vanthavasi Road,
Gandhi Nagar,
Kanchipuram - 631 501.
Cell: 94431 06470, 8056631312

மரம் வளர்ப்போம்.

மழை பெறுவோம்

Er. D.NATARAJAN, B.E.(CIVIL),M.I.E.,
 STRUCTURAL ENGINEER, CHARTERED ENGINEER
 REGISTERED&APPROVED ENGINEER
 BY THE BOARD OF ENGINEERS, TAMIL NADU.
 PANEL ENGINEER CLASS 1A, KANCHEEPURAM DISTRICT

Res: 50-A,3rd Street, S.S.Nagar.
 Palanipet, Arakkonam - 631002
 Off: #4, Vanthavasi Road,
 Gandhi nagar,
 Kanchipuram - 631501
 Cell: 9443106470, 8056631312
 Email : dnatarajan8@gmail.com

FORM - C

STATEMENT ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS
MONFORT SCHOOL, VADAKAL 'B' VILLAGE, THERESAPURAM


Form of certificate of structural soundness under Tamilnadu Combined Development and Building Rules 2019.

Certify that have inspected the building mentioned in the statement below and I have satisfied myself the building is structural sound to be used as a public building for the purpose note in the statement. The structural soundness of the building has been verified taking into account the loading as per latest Indian standard.

Location of the building door No. street name and name of the place	Age of the building	Value of the Building	No. of Storeys	Short Description of structure steel RCC framed or load bearing masonry
1.	2.	3.	4.	5.
MONFORT SCHOOL Vadakal 'B' Village, Theresapuram, Pondur Post, Sriperumbudur Taluk, Kancheepuram District - 602 105.	BLOCK I : Ground Floor : RCC : 09 & 03 Years First Floor : RCC : 08 Years Second Floor : RCC : 07 Years BLOCK III : Ground & First Floor : RCC : NEW	Rs. 1100.00 Lakhs	Ground Floor + 2	RCC Framed Structure

Purpose for which the building is certified for use	The Period for which the building will be structurally sound	No of the persons to be accommodated	Remarks
6.	7.	8.	9.
Educational Purpose	License may be issued for the period of Three Years from 01.04.2025 to 31.03.2028	1760 Pupils only	Building is structurally sound

Signature of the Correspondent


 Signature of the Engineer
 Er. D. NATARAJAN, B.E.(CIVIL),
 Chartered Engineer
 Panel Engineer Class 1A
 Kanchipuram District
 # 4, Vanthavasi Road,
 Gandhi Nagar,
 Kanchipuram - 631 501.
 Cell: 94431 06470, 8056631312

மரம் வளர்ப்போம்.

மழை பெறுவோம்

Er. D.NATARAJAN, B.E.(CIVIL),M.I.E.,
STRUCTURAL ENGINEER, CHARTERED ENGINEER
REGISTERED&APPROVED ENGINEER
BY THE BOARD OF ENGINEERS, TAMIL NADU.
PANEL ENGINEER CLASS IA, KANCHEEPURAM DISTRICT


Res: 50-A,3rd Street, S.S.Nagar.
Palanipet, Arakkonam - 631002
Off: #4, Vanthavasi Road,
Gandhi nagar,
Kanchipuram - 631501
Cell: 9443106470, 8056631312
Email : dnatarajan8@gmail.com

FORM - E

STATEMENT ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS
MONFORT SCHOOL, VADAKAL 'B' VILLAGE, THERESAPURAM

Form of report to be made to the competent authority by inspecting authorities or officers under Tamilnadu Combined Development and Building Rules 2019.

1. Name and Designation of inspecting authority or officer appointed or having jurisdiction under any other Act or law. : Er. D.NATARAJAN, B.E. (CIVIL), M.I.E.
CHARTERED ENGINEER
REGISTERED & APPROVED ENGINEER
BY THE BOARD OF ENGINEERS, TAMILNADU.
PANEL ENGINEER CLASS IA,
KANCHEEPURAM DISTRICT
2. Location of the building inspected (Door Number, Street Number, Name of place, i.e. Municipal Corporation / Municipality / Panchayat or Panchayat Union/Township/Cantonment.) : S.F.Nos. 259/1,2 & 260/7
Vadakal 'B' Village, Theresapuram, Pondur Post,
Sriperumbudur Taluk,
Kancheepuram District - 602 105.
3. Date of Inspection : 31.03.2025
4. Purpose for which the building is used : Educational Purpose
5. Nature of defects noticed : No defects found
6. Suggestions for rectifying defects : Nil
7. If in a dangerous condition, immediate : Nil


Signature of the Engineer
Er. D. NATARAJAN, B.E., M.I.E.
Chartered Engineer
Panel Engineer Class 1A
Kanchipuram District
4, Vanthavasi Road,
Gandhi Nagar,
Kanchipuram - 631 501.
Cell: 94431 06470, 8056631312

மரம் வளர்ப்போம்.

மழை பெறுவோம்